



THEIN WELL ROCHESTER, INC.
 7025 N BROADWAY AVE
 ROCHESTER, MN 55906

SE MINNESOTA WATER ANALYSIS LABORATORY
 2100 CAMPUS DR SE
 ROCHESTER, MN 55904-4722
 PHONE: (507) 328-7495
 FAX: (507) 328-7485
 EMAIL: waterlab@co.olmsted.mn.us

Report Date: 8/19/2022
 Lab Number: 34846
 Received Date: 8/15/2022
 Received Time: 12:13
 Sampled Date: 8/15/2022
 Sampled Time: 9:20
 Sampler: ASHLEY
 Sampler Title:

Unique Number: 672631
 Temp(C)@ receipt: 20.9~

Sample Name: ZUMBRO HAVEN HOA WELL #1

Sample Location: LOT 5 BLOCK 2 ORONOCO MN 55960

Reason For Test: ROUTINE

Comments: This sample meets EPA primary drinking water standards for all of the analytes tested.

Analyte	Result	Method	(LRL*)	Analyzed	Analyst
Chloride	0.6 mg/L	EPA 300.0	(0.5 mg/L)	08/15/22 21:43	oc09526
Fluoride	< 0.2 mg/L	EPA 300.0	(0.2 mg/L)	08/15/22 21:43	oc09526
Nitrate	< 0.25 mg/L	EPA 300.0	(0.25 mg/L)	08/15/22 21:43	oc09526
Nitrite	Not Detected	EPA 300.0	(0.1 mg/L)	08/15/22 21:43	oc09526
Sulfate	19.9 mg/L	EPA 300.0	(0.5 mg/L)	08/15/22 21:43	oc09526

Lauri Clements
 Digitally signed by
 Lauri Clements 2021
 Date: 2022.08.19
 14:34:16 -05'00'

Lab Analyst or Lab Manager

Laboratory Certification: MN LAB # 027-109-399 EPA LAB CODE MN00096
 SEMWAL is accredited by the Minnesota Department of Health
 Environmental Laboratory Accreditation Program and conforms to current TNI standards.
 ** = See 'Meaning of Test Results' fact sheet for additional information.
 (LRL*) = Laboratory Reporting Limit is the lowest value of the analyte that can be quantitatively determined.
 ~ = Sample received outside temperature range specified in Minnesota statutes.
 EX = Sample received outside holding time specified in EPA 300.0



MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.mvttl.com



PRELIMINARY REPORT

Report Date: 19 Aug 2022

Lab Number: 22-A42557
Work Order #: 33813
Account #: 018232
PO #: CREDIT CARD

SOUTHEASTERN MN WATER ANALYSIS LAB.
2100 CAMPUS DR SE
ROCHESTER MN 55904

Date Received: 16 Aug 2022
Time Received: 13:10
Date Sampled: 15 Aug 2022
Time Sampled: 9:20
Temperature at Receipt: 10.2
Received on Ice: Yes

Unique Well Number: 672631

Sample Description: 34846 ZUMBRO HAVEN HOA WELL #1
Site Address of Well: LOT 5 BLOCK 2 ORONOCO MN 55960

Table with 7 columns: Analyte, Results, MCL, RAL, Method, Analyzed, Analyst. Row 1: Coliform, Colilert, Absent, Absent, NA, SM 9223B-2016, 8/16/22 14:30 DAJ

MCL is defined as the Maximum Contaminant Level allowed by the Safe Drinking Water Act. RAL is the Recommended Allowable Limit. For further information, contact your state or local health department or call the EPA Safe Drinking Water Hotline 1-800-426-4791.

Approved by: [Signature]
Sarah Garza, Microbiology Lab Manager New Ulm, MN

Analyses performed under our Minnesota Department of Health Accreditation conform to the current TNI standards.

The reporting limit was elevated for any analyte requiring a dilution as coded below:
@ = Due to sample matrix # = Due to concentration of other analytes
| = Due to sample quantity + = Due to internal standard response

CERTIFICATION: MN LAB # 027-015-125 ND WW/DW # R-040

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.



THEIN WELL ROCHESTER, INC.
7025 N BROADWAY AVE
ROCHESTER, MN 55906

SE MINNESOTA WATER ANALYSIS LABORATORY
2100 CAMPUS DR SE
ROCHESTER, MN 55904-4722
PHONE: (507) 328-7495
FAX: (507) 328-7485
EMAIL: waterlab@co.olmsted.mn.us

Report Date: 8/19/2022
Lab Number: 34848
Received Date: 8/15/2022
Received Time: 12:25
Sampled Date: 8/15/2022
Sampled Time: 9:10
Sampler: ASHLEY
Sampler Title:

Unique Number: 672628
Temp(C)@ receipt: 21.0~

Sample Name: ZUMBRO HAVEN HOA WELL#2

Sample Location: LOT 5 BLOCK 9 ORONOCO MN 55960

Reason For Test: ROUTINE

Comments: This sample meets EPA primary drinking water standards for all of the analytes tested.

Analyte	Result	Method	(LRL*)	Analyzed	Analyst
Chloride	2.3 mg/L	EPA 300.0	(0.5 mg/L)	08/15/22 22:17	oc09526
Fluoride	< 0.2 mg/L	EPA 300.0	(0.2 mg/L)	08/15/22 22:17	oc09526
Nitrate	1.6 mg/L	EPA 300.0	(0.25 mg/L)	08/15/22 22:17	oc09526
Nitrite	Not Detected	EPA 300.0	(0.1 mg/L)	08/15/22 22:17	oc09526
Sulfate	20.7 mg/L	EPA 300.0	(0.5 mg/L)	08/15/22 22:17	oc09526

Digitally signed
by Lauri
Clements 2021
Date: 2022.08.19
14:31:34 -05'00'

Lab Analyst or Lab Manager

Laboratory Certification: MN LAB # 027-109-399 EPA LAB CODE MN00096
SEM WAL is accredited by the Minnesota Department of Health

Environmental Laboratory Accreditation Program and conforms to current TNI standards.

** = See 'Meaning of Test Results' fact sheet for additional information.

(LRL*) = Laboratory Reporting Limit is the lowest value of the analyte that can be quantitatively determined.

~ = Sample received outside temperature range specified in Minnesota statutes.

EX = Sample received outside holding time specified in EPA 300.0



MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.mvttl.com



PRELIMINARY REPORT

Report Date: 19 Aug 2022

Lab Number: 22-A42556
Work Order #: 33813
Account #: 018232
PO #: CREDIT CARD

SOUTHEASTERN MN WATER ANALYSIS LAB.
2100 CAMPUS DR SE
ROCHESTER MN 55904

Date Received: 16 Aug 2022
Time Received: 13:10
Date Sampled: 15 Aug 2022
Time Sampled: 9:10
Temperature at Receipt: 10.2
Received on Ice: Yes

Unique Well Number: 672628

Sample Description: 34848 ZUMBRO HAVEN HOA WELL #2
Site Address of Well: LOT 5 BLOCK 9 ORONOCO MN 55960

Table with 7 columns: Analyte, Results, MCL, RAL, Method, Analyzed, Analyst. Row 1: Coliform, Colilert, Absent, Absent, NA, SM 9223B-2016, 8/16/22 14:30 DAJ

MCL is defined as the Maximum Contaminant Level allowed by the Safe Drinking Water Act. RAL is the Recommended Allowable Limit. For further information, contact your state or local health department or call the EPA Safe Drinking Water Hotline 1-800-426-4791.

Approved by: [Signature]
Sarah Garza, Microbiology Lab Manager New Ulm, MN

Analyses performed under our Minnesota Department of Health Accreditation conform to the current TNI standards.

The reporting limit was elevated for any analyte requiring a dilution as coded below:
@ = Due to sample matrix # = Due to concentration of other analytes
! = Due to sample quantity + = Due to internal standard response

CERTIFICATION: MN LAB # 027-015-125 ND WW/DW # R-040

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.



SE MINNESOTA WATER ANALYSIS LABORATORY
 2100 CAMPUS DR SE
 ROCHESTER, MN 55904-4722
 PHONE: (507) 328-7495
 FAX: (507) 328-7485
 EMAIL: waterlab@co.olmsted.mn.us

ZUMBRO HAVEN HOA WELL #3
 LT 4 BLOCK 8
 ORONOCO, MN 55960

Report Date: 8/19/2022
 Lab Number: 34845
 Received Date: 8/15/2022
 Received Time: 12:00
 Sampled Date: 8/15/2022
 Sampled Time: 9:36
 Sampler: ASHLEY
 Sampler Title:

Unique Number: 672632
 Temp(C)@ receipt: 20.1~

Sample Name: ZUMBRO HAVEN HOA WELL #3

Sample Location: LT 4 BLOCK 8 ORONOCO MN 55960

Reason For Test: ROUTINE

Comments: This sample meets EPA primary drinking water standards for all of the analytes tested.

Analyte	Result	Method	(LRL*)	Analyzed	Analyst
Chloride	1 mg/L	EPA 300.0	(0.5 mg/L)	08/15/22 21:26	oc09526
Fluoride	< 0.2 mg/L	EPA 300.0	(0.2 mg/L)	08/15/22 21:26	oc09526
Nitrate	0.4 mg/L	EPA 300.0	(0.25 mg/L)	08/15/22 21:26	oc09526
Nitrite	Not Detected	EPA 300.0	(0.1 mg/L)	08/15/22 21:26	oc09526
Sulfate	20.2 mg/L	EPA 300.0	(0.5 mg/L)	08/15/22 21:26	oc09526

Digitally signed by
 Lauri Clements
 2021
 Date: 2022.08.19
 14:29:05 -05'00'
 Lab Analyst or Lab Manager

Laboratory Certification: MN LAB # 027-109-399 EPA LAB CODE MN00096
 SEMWAL is accredited by the Minnesota Department of Health
 Environmental Laboratory Accreditation Program and conforms to current TNI standards.
 ** = See 'Meaning of Test Results' fact sheet for additional information.
 (LRL*) = Laboratory Reporting Limit is the lowest value of the analyte that can be quantitatively determined.
 ~ = Sample received outside temperature range specified in Minnesota statutes.
 EX = Sample received outside holding time specified in EPA 300.0



MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.mvttl.com



PRELIMINARY REPORT

Report Date: 19 Aug 2022

Lab Number: 22-A42553
Work Order #: 33813
Account #: 018232
PO #: CREDIT CARD

SOUTHEASTERN MN WATER ANALYSIS LAB.
2100 CAMPUS DR SE
ROCHESTER MN 55904

Date Received: 16 Aug 2022
Time Received: 13:10
Date Sampled: 15 Aug 2022
Time Sampled: 9:36
Temperature at Receipt: 10.2
Received on Ice: Yes

Sample Description: 34845 ZUMBRO HAVEN HOA WELL #3
Site Address of Well: LT 4 BLOCK 8 ORONOCO MN 55960

Table with 7 columns: Analyte, Results, MCL, RAL, Method, Analyzed, Analyst. Row 1: Coliform, Colilert, Absent, Absent, NA, SM 9223B-2016, 8/16/22 14:30 DAJ

MCL is defined as the Maximum Contaminant Level allowed by the Safe Drinking Water Act. RAL is the Recommended Allowable Limit. For further information, contact your state or local health department or call the EPA Safe Drinking Water Hotline 1-800-426-4791.

Approved by: [Signature]
Sarah Garza, Microbiology Lab Manager New Ulm, MN

Analyses performed under our Minnesota Department of Health Accreditation conform to the current TNI standards.

The reporting limit was elevated for any analyte requiring a dilution as coded below:
@ = Due to sample matrix # = Due to concentration of other analytes
! = Due to sample quantity + = Due to internal standard response

CERTIFICATION: MN LAB # 027-015-125 ND WWDW # R-040

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.



THEIN WELL ROCHESTER, INC.
7025 N BROADWAY AVE
ROCHESTER, MN 55906

SE MINNESOTA WATER ANALYSIS LABORATORY
2100 CAMPUS DR SE
ROCHESTER, MN 55904-4722
PHONE: (507) 328-7495
FAX: (507) 328-7485
EMAIL: waterlab@co.olmsted.mn.us

Report Date: 8/19/2022
Lab Number: 34847
Received Date: 8/15/2022
Received Time: 12:18
Sampled Date: 8/15/2022
Sampled Time: 9:50
Sampler: ASHLEY
Sampler Title:

Unique Number: 672629
Temp(C)@ receipt: 20.5~

Sample Name: ZUMBRO HAVEN HOA WELL #4

Sample Location: LOT 4 BLOCK 4 ORONOCO MN 55960

Reason For Test: ROUTINE

Comments: This sample meets EPA primary drinking water standards for all of the analytes tested.

Analyte	Result	Method	(LRL*)	Analyzed	Analyst
Chloride	6.6 mg/L	EPA 300.0	(0.5 mg/L)	08/15/22 22:00	oc09526
Fluoride	< 0.2 mg/L	EPA 300.0	(0.2 mg/L)	08/15/22 22:00	oc09526
Nitrate	4 mg/L	EPA 300.0	(0.25 mg/L)	08/15/22 22:00	oc09526
Nitrite	Not Detected	EPA 300.0	(0.1 mg/L)	08/15/22 22:00	oc09526
Sulfate	22.8 mg/L	EPA 300.0	(0.5 mg/L)	08/15/22 22:00	oc09526

Lauri Clements
Digitally signed by
Lauri Clements 2021
Date: 2022.08.19
14:42:01 -05'00'

Lab Analyst or Lab Manager

Laboratory Certification: MN LAB # 027-109-399 EPA LAB CODE MN00096

SEM WAL is accredited by the Minnesota Department of Health
Environmental Laboratory Accreditation Program and conforms to current TNI standards.

** = See 'Meaning of Test Results' fact sheet for additional information.

(LRL*) = Laboratory Reporting Limit is the lowest value of the analyte that can be quantitatively determined.

~ = Sample received outside temperature range specified in Minnesota statutes.

EX = Sample received outside holding time specified in EPA 300.0



MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.mvttl.com



PRELIMINARY REPORT

Report Date: 19 Aug 2022

Lab Number: 22-A42554
Work Order #: 33813
Account #: 018232
PO #: CREDIT CARD

SOUTHEASTERN MN WATER ANALYSIS LAB.
2100 CAMPUS DR SE
ROCHESTER MN 55904

Date Received: 16 Aug 2022
Time Received: 13:10
Date Sampled: 15 Aug 2022
Time Sampled: 9:50
Temperature at Receipt: 10.2
Received on Ice: Yes

Unique Well Number: 672629

Sample Description: 34847 ZUMBRO HAVEN HOA WELL #4
Site Address of Well: LT 4 BLOCK 4 ORONOCO MN 55960

Table with 7 columns: Analyte, Results, MCL, RAL, Method, Analyzed, Analyst. Row 1: Coliform, Colilert, Absent, Absent, NA, SM 9223B-2016, 8/16/22 14:30 DAJ

MCL is defined as the Maximum Contaminant Level allowed by the Safe Drinking Water Act. RAL is the Recommended Allowable Limit. For further information, contact your state or local health department or call the EPA Safe Drinking Water Hotline 1-800-426-4791.

Approved by: [Signature]
Sarah Garza, Microbiology Lab Manager New Ulm, MN

Analyses performed under our Minnesota Department of Health Accreditation conform to the current TNI standards.

The reporting limit was elevated for any analyte requiring a dilution as coded below:
@ = Due to sample matrix # = Due to concentration of other analytes
l = Due to sample quantity + = Due to internal standard response

CERTIFICATION: MN LAB # 027-015-125 ND WW/DW # R-040

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.



THEIN WELL ROCHESTER, INC.
 7025 N BROADWAY AVE
 ROCHESTER, MN 55906

SE MINNESOTA WATER ANALYSIS LABORATORY
 2100 CAMPUS DR SE
 ROCHESTER, MN 55904-4722
 PHONE: (507) 328-7495
 FAX: (507) 328-7485
 EMAIL: waterlab@co.olmsted.mn.us

Report Date: 8/19/2022
 Lab Number: 34844
 Received Date: 8/15/2022
 Received Time: 11:51
 Sampled Date: 8/15/2022
 Sampled Time: 10:20
 Sampler: ASHLEY
 Sampler Title:

Unique Number: 672630
 Temp(C)@ receipt: 20.5~

Sample Name: ZUMBRO HAVEN HOA WELL #5

Sample Location: LOT 1 BLOCK 7 ORONOCO MN 55960

Reason For Test: ROUTINE

Comments: This sample meets EPA primary drinking water standards for all of the analytes tested.

Analyte	Result	Method	(LRL*)	Analyzed	Analyst
Chloride	7.2 mg/L	EPA 300.0	(0.5 mg/L)	08/15/22 20:34	oc09526
Fluoride	< 0.2 mg/L	EPA 300.0	(0.2 mg/L)	08/15/22 20:34	oc09526
Nitrate	3.8 mg/L	EPA 300.0	(0.25 mg/L)	08/15/22 20:34	oc09526
Nitrite	Not Detected	EPA 300.0	(0.1 mg/L)	08/15/22 20:34	oc09526
Sulfate	21.9 mg/L	EPA 300.0	(0.5 mg/L)	08/15/22 20:34	oc09526

Lauri Clements
 Digitally signed by
 Lauri Clements 2021
 Date: 2022.08.19
 14:18:39 -05'00'

Lab Analyst or Lab Manager

Laboratory Certification: MN LAB # 027-109-399 EPA LAB CODE MN00096
 SEMWAL is accredited by the Minnesota Department of Health
 Environmental Laboratory Accreditation Program and conforms to current TNI standards.
 ** = See 'Meaning of Test Results' fact sheet for additional information.
 (LRL*) = Laboratory Reporting Limit is the lowest value of the analyte that can be quantitatively determined.
 ~ = Sample received outside temperature range specified in Minnesota statutes.
 EX = Sample received outside holding time specified in EPA 300.0



MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.mvtl.com



PRELIMINARY REPORT

Report Date: 19 Aug 2022

Lab Number: 22-A42555
Work Order #: 33813
Account #: 018232
PO #: CREDIT CARD

SOUTHEASTERN MN WATER ANALYSIS LAB.
2100 CAMPUS DR SE
ROCHESTER MN 55904

Date Received: 16 Aug 2022
Time Received: 13:10
Date Sampled: 15 Aug 2022
Time Sampled: 10:20
Temperature at Receipt: 10.2
Received on Ice: Yes

Unique Well Number: 672630

Sample Description: 34844 ZUMBRO HAVEN HOA WELL #5
Site Address of Well: LT 1 BLOCK 7 ORONOCO MN 55960

Table with 7 columns: Analyte, Results, MCL, RAL, Method, Analyzed, Analyst. Row 1: Coliform, Colilert, Absent, Absent, NA, SM 9223B-2016, 8/16/22 14:30 DAJ

MCL is defined as the Maximum Contaminant Level allowed by the Safe Drinking Water Act. RAL is the Recommended Allowable Limit. For further information, contact your state or local health department or call the EPA Safe Drinking Water Hotline 1-800-426-4791.

Approved by: [Signature]
Sarah Garza, Microbiology Lab Manager New Ulm, MN

Analyses performed under our Minnesota Department of Health Accreditation conform to the current TNI standards.

The reporting limit was elevated for any analyte requiring a dilution as coded below:
@ = Due to sample matrix # = Due to concentration of other analytes
! = Due to sample quantity + = Due to internal standard response

CERTIFICATION: MN LAB # 027-015-125 ND WW/DW # R-040

MVTl guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.